

ONTARIO ELECTRICAL SAFETY CODE REQUIREMENTS

Provided by: Electrical Safety Authority

PLEASE READ AND UNDERSTAND THESE REGULATIONS. YOUR EQUIPMENT WILL BE INSPECTED AT THE FAIR.

- 1) The Ontario Electrical Safety Code, 23rd Edition, 2002, specifically Section 2, under Rules 2-022 and 2-024 requires all electrical equipment to be approved before it may be lawfully advertised, displayed, offered for sale, sold or otherwise disposed of/used in the Province of Ontario. **If your product is not approved or electrically safe it will not be connected.**

Unapproved electrical equipment shall be permitted to be displayed at trade shows when permission is given by the Inspection Department. (For Trade Show Permission call: 1-877-421-2228)

- 2) Ontario Regulation 11/02, under the Electricity Act, 1998, appoints the Electrical Safety Authority as the Regulator responsible for enforcement of the Ontario Electrical Safety Code in the Province of Ontario.
- 3) It is therefore the responsibility of each exhibitor, concessionaire and/or ride operator to ensure that all electrical equipment complies with the above regulations. This includes all electrical motors and equipment as well as lighting and display equipment. All lighting fixtures must have an approved cord or be wired with an approved box.
- 4) Electrical equipment for which approval is sought shall be submitted to:

Canadian Standards Association
178 Rexdale Blvd.
Rexdale, ON M9W 1R3

The approval of this Association or other accredited organization (see attached) is acceptable to all electrical inspection authorities in Canada. You are referred to them for details of procedure.

- 5) One of the fundamental requirements for certification is that all the appropriate approval markings must appear on each device. If such markings are missing, the device must be considered unapproved and therefore subject to special inspection.
- 6) If you wish to display, offer for sale, or use, any electrical equipment which is not now certified by an agency accredited by the Standards Council of Canada, it is first necessary to submit same to a field approved agency for approval, by means of their Special Inspection Services.
- 7) Should any of this equipment not conform, it is recommended that you request temporary permission to exhibit or use while the necessary approval certification is being sought. Please write directly to:















Field Evaluation Services PH: 1-800-559-5356
Electrical Safety Authority FX: 1-800-559-5358
P.O. Box 24143
Pinebush Postal Outlet
Cambridge, ON N1R 8E6

FOR ADDITIONAL INFORMATION CONCERNING THESE REGULATIONS







See the ESA internet web site at, www.esainspection.net

Failure of electrical equipment to comply with the Ontario Electrical Safety Code Requirements can result in the equipment being refused connection to the source of electrical supply and it may even be ordered removed.

CERTIFICATION MARKS ACCEPTABLE UNDER
THE ELECTRICAL SAFETY CODE

Canadian Standards Association (CSA)	   
Entela	
Intertek Testing Services	 
Met Laboratories Inc. (MET)	
OMNI Environmental Services Inc.	
Quality Auditing Institute	
TUV Rheinland	
Underwriters Laboratories Inc. (UL)	 
Underwriters' Laboratories of Canada (ULC)	

FIELD EVALUATION MARKS ACCEPTABLE UNDER
THE ELECTRICAL SAFETY CODE

<p>CANADIAN STANDARDS ASSOCIATION (CSA)</p>		<p>INTERTEK TESTING SERVICES</p>	
<p>ELECTRICAL SAFETY AUTHORITY (ESA)</p>		<p>ONTARIO HYDRO (OH)</p>	
<p>ENTE LA</p>		<p>UNDERWRITERS LABORATORIES OF CANADA (ULC)</p>	
<p>INTERNATIONAL APPROVAL SERVICES (IAS)</p>	